

आयुक्त, पनवेल महानगरपालिका खालील नमूद कामाकरीता अंदाजपत्रक तयार करण्यासाठी खालील कामासाठी दरपत्रक (Market Rate) मागविण्यात येत आहेत.

Sr. No.	Description	Quantity	Unit	Rate	Amount
				(Rs. Ps)	(Rs. Ps)
1	Supplying, erecting, testing and commissioning of diesel generating set with alternator and CPCB IV + compatible (DG set that meets the specific environment and emission standards mandated by the CPCB of India) of 82.5 kVA output continuous rating, 3 Phase, 415 V, 50c/s 0.8 p. f.A.C supply, a totally enclosed air cooled / liquid cooled multi-cylinder diesel engine developing suitable BHP at 1500 rpm with 10% overload for 1 hour in 12 hours, along with standard accessories, self-excited, self-regulated, screen-protected alternator with static excitation system running at 1500 RPM as per IS4722-2001 with voltage regulation +/- 5 %, with performance class G2 and maximum fuel consumption 14.0 Ltr/hr @75% loading . Both the engine and alternator direct coupled on a common fabricated steel base frame and mounted on anti-vibrating pads with standard control panel comprising meters, switchgears, indicators connected with suitable wires/cables, the complete set enclosed in composite Acoustic enclosure as fully assembled integral unit made of 16 SWG CRCA Sheet, sound absorbing material to restrict sound level up to 75dB(A) at 1.0 m, provided with first filling of oil, diesel not less than 145 Ltr etc. on provided M20 Grade CC Foundation.	1	No.		
2a	Supplying, erecting, testing and commissioning of microprocessor based AMF panel suitable for diesel generating set of above 82.5 kVA up to 100 kVA capacity Three phase, 415 Volts, 50Hz A.C. with all standard features, safeties etc.	1	No.		
2b	Supplying and erecting mains with 3x2.5 sq.mm FRLSH copper PVC insulated wire in provided conduit / trunking / inside pole / Busbars or any other places as per specification No: WG-MA/BW	1	Mtr		
2c	Supplying and laying (including excavation of suitable width & depth upto 90 cm) 50 mm outside dia. double wall corrugated pipes (DWC) of HDPE for enclosing cable below ground/road surface, to required depth complete.	1	Mtr		
Total Amount					

सदर डिझेल जनरेटिंग सेट (DG Set) महाराष्ट्र प्रदूषण नियंत्रण विभागाच्या परिपत्रक क्र. MPCB/JD(APC)/NCAP/DG set/B-००९० दि. ०२.०६.२०२३ ला अनुसरून असणे अनिवार्य आहे.

निविदा कालावधी: ११/०९/२०२६ ते १८/०९/२०२६ (०८ दिवस)

या कामाच्या दरपत्रकाबाबतची माहिती पनवेल महानगरपालिकेच्या www.panvelcorporation.maharashtra.gov.in या संकेतस्थळावर दि. १०/०९/२०२६ रोजी प्रसिध्द करण्यात येईल. सदर बाबींचे बाजार भाव स्वतःच्या लेटरहेडवर महानगरपालिका कार्यालयात अथवा pmcbandhkamdept01@gmail.com व cltcmaypanvel@gmail.com या ई-मेलवर मुदतीत पाठविण्यात यावे ही विनंती. सदर दर हे अंदाजपत्रक तयार करण्यासाठी आहेत. याची कृपया नोंद घ्यावी.


शहर अभियंता
पनवेल महानगरपालिका